

This safety certificate is an important and valuable document which should be retained for future reference

This certificate is not valid if the serial number has been defaced or altered **DCN6/0881107**

## DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with British Standard 7671 - Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable, LU5 5ZX

### DETAILS OF THE CLIENT

Client and address  
Martyn Gruneberg  
14 Newton Street  
Blairgowrie

Postcode: PH10 6DJ

### ADDRESS OF THE INSTALLATION

Installation address  
14 Newton Street  
Blairgowrie

Postcode: PH10 6DJ

### DETAILS OF THE INSTALLATION

Extent of the installation work covered by this certificate  
DB replaced and EICR carried out previous to that.  
Smoke and CO detection installed.

The installation is:  
New ☐  
An addition ☐  
An alteration ☒

### DESIGN, CONSTRUCTION, INSPECTION AND TESTING

I/We being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my/our signatures adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing hereby CERTIFY that the said work for which I/we have been responsible is to the best of my/our knowledge and belief, in accordance with BS 7671, 2008 mmended to 2008 te) except for the departures, if any, detailed as follows:

Details of departures from BS 7671, as amended (Regulations 120.3, 133.5)

N/A

The extent of liability of the signatory is limited to the work described above as the subject of this certificate. For the **DESIGN** the **CONSTRUCTION** and the **INSPECTION AND TESTING** of the installation.

Signature  Name (CAPITALS) GRANT ROBBIE Date 28/04/2016

The results of the inspection and testing reviewed by the Qualified Supervisor

Signature  Name (CAPITALS) KEVIN DONACHIE Date 28/04/2016

### PARTICULARS OF THE APPROVED CONTRACTOR

Trading Title  
Kevin Donachie Electricians

Address  
29 Honeyberry Crescent  
Rattray  
Perthshire

Telephone No: 01250 872792

Postcode: PH10 7RD



NICEIC Enrolment No  
(Essential information) 010160000

Branch No  
(if applicable) N/A

### NEXT INSPECTION

§ Enter interval in terms of years, months or weeks, as appropriate

I RECOMMEND that this installation is further inspected and tested after an interval of not more than § 5 Years

### COMMENTS ON EXISTING INSTALLATION

Note: Enter 'NONE' or, where appropriate, the page number(s) of additional page(s) of comments on the existing installation

None

In the case of an alteration or additions see section 633 of BS7671

### SCHEDULE OF ADDITIONAL RECORDS\*

See attached schedule

N/A

\* Where the electrical work to which this certificate relates includes the installation of a fire alarm system and/or an emergency lighting system (or part of such systems), this electrical safety certificate should be accompanied by the particular certificate(s) for the system(s)

Please see the 'Notes for Recipients'

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Original (To the person ordering the work)

SUPPLY CHARACTERISTICS				Nature of supply parameters				Characteristics of primary supply overcurrent protective device(s)			
System type(s)		Number and type of live conductors		Number of sources		Nominal voltage(s)		Nominal frequency, f <sup>(1)</sup>		BS(EN)	
TN-S <input checked="" type="checkbox"/>		1-phase (2-wire) N/A		1		U <sup>(1)</sup> 230 V		50 Hz		BS 1361 Fuse HBC Domestic Type 2	
TN-C-S N/A		3-phase (3-wire) N/A				U <sub>0</sub> <sup>(1)</sup> 230 V		External earth fault loop impedance, Z <sub>e</sub> <sup>(1)</sup>		Type 2	
TT N/A		Other <input type="text"/>		Single-phase		Prospective fault current, I <sub>pf</sub> <sup>(2)(3)</sup> 1.08 kA		3-phase		Rated current 100 A Short-circuit capacity 16.5 kA	

PARTICULARS OF INSTALLATION AT THE ORIGIN										Main switch or circuit breaker			
Means of earthing		Details of installation earth electrode (where applicable)				Protective measures for fault protection		Measured Z <sub>e</sub>		Type BS(EN)			
Distributor's facility <input checked="" type="checkbox"/>		Type (eg rod(s), tape etc) N/A Location N/A				ADS		0.21 Ω		BS EN 60947-			
Installation earth electrode N/A		Electrode resistance, R <sub>A</sub> N/A Ω Method of measurement N/A						Maximum demand load 63 Amps		Voltage rating 230 V			
Earthing conductor		Continuity/connection verified		Main protective bonding conductors and bonding of extraneous parts (✓)						No of poles 2			
Conductor material Copper		<input checked="" type="checkbox"/>		Conductor material Copper		Conductor csa 10 mm <sup>2</sup>		Water service <input checked="" type="checkbox"/>		Rated current, I <sub>n</sub> 100 A			
Conductor csa 16 mm <sup>2</sup>		<input checked="" type="checkbox"/>		Location N/A				Oil service N/A		Supply conductors material Copper			
		<input checked="" type="checkbox"/>						Gas service <input checked="" type="checkbox"/>		RCD operating current, I <sub>Δn</sub> * N/A mA			
		<input checked="" type="checkbox"/>						Structural steel N/A		Supply conductors csa 25 mm <sup>2</sup>			
		<input checked="" type="checkbox"/>						Other incoming service(s) N/A		RCD operating time (at I <sub>Δn</sub> )* N/A ms			

\* applicable only where an RCD is used as a main circuit-breaker

SCHEDULE OF ITEMS INSPECTED		Additional protection		Cables and conductors (cont)		SCHEDULE OF ITEMS TESTED	
Protective measures against electric shock		<input checked="" type="checkbox"/> Presence of residual current device(s)		<input checked="" type="checkbox"/> Routing of cables in prescribed zones		<input checked="" type="checkbox"/> External earth fault loop impedance, Z <sub>e</sub>	
Basic and fault protection		<input checked="" type="checkbox"/> Presence of supplementary bonding conductors		<input checked="" type="checkbox"/> Cables incorporating earthing armour or sheath or run in an earthed wiring system, or otherwise protected against nails, screws and the like		N/A Installation earth electrode resistance, R <sub>A</sub>	
Extra low voltage Double or reinforced insulation <input checked="" type="checkbox"/> SELV		Prevention of mutual detrimental influence		<input checked="" type="checkbox"/> Additional protection by 30mA RCD (where required, in premises not under the supervision of skilled or instructed persons)		<input checked="" type="checkbox"/> Continuity of protective conductors	
<input checked="" type="checkbox"/> Double or reinforced insulation		<input checked="" type="checkbox"/> Proximity of non-electrical services and other influences		<input checked="" type="checkbox"/> Connection of conductors		<input checked="" type="checkbox"/> Continuity of ring final circuit conductors	
Basic protection		<input checked="" type="checkbox"/> Segregation of Band I and Band II circuits of Band II insulation used		<input checked="" type="checkbox"/> Presence of fire barriers, suitable seals and protection against thermal effects		<input checked="" type="checkbox"/> Insulation resistance between live conductors	
<input checked="" type="checkbox"/> Insulation of live parts N/A Barriers or enclosures		N/A Segregation of safety circuits		General		<input checked="" type="checkbox"/> Insulation resistance between live conductors and earth	
Fault protection		Identification		<input checked="" type="checkbox"/> Presence and correct location of appropriate devices for isolation and switching		<input checked="" type="checkbox"/> Polarity	
Automatic disconnection of supply		<input checked="" type="checkbox"/> Presence of diagrams, instructions, circuit charts and similar information		<input checked="" type="checkbox"/> Adequacy of access to switchgear and other equipment		<input checked="" type="checkbox"/> Earth fault loop impedance, Z <sub>s</sub>	
<input checked="" type="checkbox"/> Presence of earthing conductor		<input checked="" type="checkbox"/> Presence of danger notices		<input checked="" type="checkbox"/> Particular protective measures for special installations and locations		N/A Verification of phase sequence	
<input checked="" type="checkbox"/> Presence of circuit protective conductors		<input checked="" type="checkbox"/> Presence of other warning notices, including presence of mixed wiring colours		<input checked="" type="checkbox"/> Connection of single-pole devices for protection or switching in line conductors only		<input checked="" type="checkbox"/> Operation of residual current device(s)	
<input checked="" type="checkbox"/> Presence of main protective bonding conductors		<input checked="" type="checkbox"/> Labelling of protective devices, switches and terminals		<input checked="" type="checkbox"/> Correct connections of accessories and equipment		<input checked="" type="checkbox"/> Functional testing of assemblies	
N/A Presence of adequate arrangements for other source(s), where applicable		<input checked="" type="checkbox"/> Identification of conductors		<input checked="" type="checkbox"/> Selection of equipment and protective measures appropriate to external influences		N/A Verification of voltage drop	
<input checked="" type="checkbox"/> Choice and setting of protective devices (for fault protection and/or overcurrent)		Cables and conductors		<input checked="" type="checkbox"/> Selection of appropriate functional switching devices			
Electrical separation		<input checked="" type="checkbox"/> Selection of conductors for current carrying capacity and voltage drop					
<input checked="" type="checkbox"/> For one item of current-using equipment		<input checked="" type="checkbox"/> Erection methods					

† See note below

† All boxes must be completed. '✓' indicates that an inspection or a test was carried out and that the result was satisfactory. 'N/A' indicates that an inspection or a test was not applicable to the particular installation.  
‡ Where a smoke alarm has been installed, separate certification is required on the appropriate form.

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

[illegible]

TEST INSTRUMENTS		Test instrument (serial numbers) used									
Multi-function	611175407111073322	Insulation resistance	N/A	Continuity	N/A	Earth electrode resistance	N/A	Earth fault loop impedance	N/A	RCD	N/A